

MIT ACCUMULATION TANKS TECHNICAL SPECIFICATIONS

1-Accumulation tanks should be produced as vertical style.

2-Conditions of TSE and DIN must be provided.

3-Strength of accumulation tanks against temperature and pressure should be as below;

Maximum operation pressure :10 bar

Maximum operation temperature :95 °C

4- Accumulation tanks must have CE documents.

5- Magnesium anode and enameled cover must have corrosion protection according to DIN 4753-3.

6-There should be a cleaning and observation cover and tank must have a suitable port for electrical heater assembly.

7-There must be sheet metal with dyed electrostatic paint which is on polyurethane foam from 100 lt till 800lt and from 800lt till 2000 lt , there must be artificial leather cover which is on soft polyurethane foam .

8-Tanks must be suitable for every kind of drinking water.